

Compliance Statement

No. 2025-030

Unscreened Channel, Class E

Company

AGER ENDÜSTRİYEL METAL ÜRÜNLER SANAYİ ve TİCARET LİMİTED ŞİRKETİ
75. YIL MAHALLESİ O.S.B BÖLGESİ 22. CADDE NO:2
26250 ESKİŞEHİR/TÜRKİYE

Channel Identification (4 connector model)

Horizontal cable:

AGER U/UTP Cat6 LSZH Installation Cable
Part no. AC-600-5-XX (XX-Color)

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

AGER UTP Cat6 Keystone Jack
Part no. AC-6XX-YYZZ
(XX-Catagory, YY-Function, ZZ-Option)

Terminal cord, consolidation point cord, patch cord and equipment cord:

AGER U/UTP Cat6 Patch Cord Terminal cord, Part no. AC-602-050
Consolidation point cord, Part no. AC-602-050 (with jack AC-601 added)
Patch cord, Part no. AC-602-020
Equipment cord, Part no. AC-602-020 (with jack AC-601 added)
Coding: AC-6XX-YYYYZZ XX=Catagory, YYYY=Length, ZZ=Color

Generic cabling standards - Class E Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12521960, DANAK-19/24750

EC Cabling product ID


7744

CS valid until

1 February 2026

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 30 January 2025



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

